



Government of Bermuda  
Ministry of Public Works  
Department of Public Lands and Building

**Addenda**  
**For**  
**DARRELL'S ISLAND BATHROOM RENOVATIONS**

Procurement No.: **2024-005Q-MPW**

Issued: **July 19, 2024**

Submission Deadline: **August 26, 2024, 03:00 P.M.**

Addenda No. **0001**

**Addenda Type: Date and Specification Clarifications**

The following addendum supersedes information contained in the solicitation document issued for this procurement to the extent referenced. This Addendum forms part of the solicitation documents and will be subject to all the conditions set out in the contract conditions.

**Date Changes as shown below:**

- 1) 2nd Site visit is Thursday August 15, 2024, at 10:00 a.m. Boat leaves Darrell's Wharf at 10:00 a.m. sharp.**
- 2) Deadline for Questions Thursday August 22, 2024**
- 3) Deadline for Issuing Addenda Tuesday August 27, 2024**
- 4) Submission deadline Wednesday September 4, 2024, 3:00 p.m. local time**
- 5) Contract Negotiation 14 calendar days**
- 6) Anticipated Execution of Agreement Friday November 1, 2024**
- 7) Annex B has been Update see attached**

**DESCRIPTION: SPECIFICATION CLARIFICATION:**

**1. Toilet Partitions**

- **Scope:** Existing partitions do not need to be demolished.

**2. Pumphouse/Electrical Room**

- Install PVC full louvred doors.
- Doors must have single-keyed locks and single-cylinder deadbolt locks (Supply and Install)

**3. Electrical**

- Upgrade the existing electrical system to ensure compliance with current electrical codes.
- Reroute the cable currently hanging from the bathroom to the dormitory by installing it underground for improved safety and aesthetics.
- Install a 24-circuit panel, 1 phase 120/240v (Supply and Install)

**4. Wall Tiling**

- Wall tiles in the shower area will be installed at the same height as when the previous tiles were removed.

**5. Entrance Doors**

- All doors must have a single keyed lock and single cylinder deadbolt lock. (Supply and install)

**6. Toilet Partition Doors**

- All doors must have a 2-piece bathroom stall door latch with a vacant or engaged indicator. (Supply and install)

**End of Addenda No:0001**