



Government of Bermuda  
Ministry of Public Works  
Department of Works and Engineering

**Addenda**  
**For**  
**KINDLEY FIELD BOAT RAMP REPAIR**

Procurement No.: 2024-006Q-MPW

Issued: Mon, 12/16/2024

Submission Deadline: Mon, 01/20/2025, 03:00 P.M.

**Addenda No. 0003**

**Addenda Type: Question and Answers**

The following addendum supersedes information contained in the solicitation document issued for this procurement to the extent referenced. This Addendum forms part of the solicitation documents and will be subject to all the conditions set out in the contract conditions.

**Bidder's Questions (Q) and Government's Responses (A) are shown below**

Q

1. Could you clarify the purpose of the boulders placed at the end of the ramp? It is unclear how they relate to the functionality of the boat ramp itself.

A

The underlying material is fill, so the boulders provide scour protection. Secondary function is a wheel stop, so they should sit slightly proud of the toe surface. Not expected to stop a runaway trailer, but enough to give feedback as driver reverses.

Q

2. Additionally, we would like to understand the purpose of the cemented boulder/rock perimeter protection. Would formwork be a more suitable option for this element?

A

Scour protection. Alternatives will be considered; please give thorough description of any alternatives or substitutes with your proposal.