



Department of Public Lands & Buildings

Page 1 of 1

COIL REPLACEMENT AND SYSTEM UPGRADES TO DLBE HVAC PLANT: ADDENDUM No. 1

DATE: OCTOBER 6th, 2021

METHOD OF DELIVERY: EMAIL

PROJECT NAME & NO.: Coil Replacement and System Upgrades to DLBE HVAC Plant

RE: Tender Scope Change

TO: All Bidding General Contractors

The following information supplements and/or supersedes the Tender documents dated September 24th 2021

This Addendum forms part of the contract documents and is to be read, interpreted and coordinated with all other parts. The cost of all work contained herein is to be included in the contract sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above named project to the extent referenced and shall become part thereof. Acknowledge receipt of this addendum by inserting its number and date on the Request for Quote. Failure to do so may subject the bidder to disqualification.

No. : DESCRIPTION:

A. REVISE Tender Submission Deadline to 3:00pm Friday, 22nd of October 2021.

B. REVISE Scope of works as follows:

- **All condenser coils, condensers and fan motors to be replaced**
- **One HVAC unit to remain operational at all times to provide conditioned air to the building while unit change-outs are being performed**
- **All vibration isolators to be replaced**
- **Rusting on unit stands to be repaired and primed where needed with a gray structural metal primer**
- **Omit replacement of 16 ball valves, existing ball valves to remain in place**

End of Addendum 1