

TYPICAL VALVE BOX DETAILS
N.T.S.

MIN 5" THK LAYER OF NEW ASPHALT
SURFACE TO MATCH EXISTING FINISHED
SURFACE ELEVATION WHERE APPLICABLE

CLEAN BACKFILL TO BE COMPACTED IN
MAXIMUM 8" LIFTS

EDGE OF NEW TRENCH

NEW 4"8 HDPE PIPE
MPW WATERMAIN

BEDDING MATERIAL FOR NEW 4"8 PIPES
TO BE CLEAN, WELL COMPACTED SCREENINGS

SURFACE TO MATCH EXISTING

CROSS-SECTION OF NEW TRENCH


N.T.S.

THE MINISTRY OF PUBLIC WORKS

P.O. Box HM525 Hamilton HMCX Bermuda Phone: (441)295-5151

> DEPARTMENT OF WORKS & ENGINEERING Fax: (441)294-9087

Water & Sewage Section



SHEET TITLE:

DEVONSHIRE

PROJECT NAME:

TRENCH-DETAILS

AEOLIA-DRIVE WATERMAIN REPLACEMENT

AD02

